



CERTIFICATE OF CONSTANCY OF PERFORMANCE

Product	weldable hot rolled reinforcing steel bars
Type	B500B, diameters 10, 12, 14, 16, 20, 25, 28 and 32 mm
Intended use(s)	for the reinforcement of concrete structures
Performances	see annex 1
Manufacturer	ArcelorMittal Warszawa Sp. z o.o., 132, Kasprowicza Street, 01-949 Warsaw, Poland
Manufacturing plant	ArcelorMittal Warszawa Sp. z o.o., 132, Kasprowicza Street, 01-949 Warsaw, Poland
Requirements	LST EN 10080:2006 and declared by the producer performances

This certificate is issued having performed actions prescribed for system 1+ in STR 1.01.04:2015 and confirms that the product complies with requirements set out in this certificate.

Number	SPSC-9064
Date of issue	2025-01-23 (first issued on 2012-01-31)
Valid until	2028-01-23 (information www.spsc.lt)
Granted to	ArcelorMittal Warszawa Sp. z o.o., 132, Kasprowicza Street, 01-949 Warsaw, Poland, company code 010592085

Director



Valdemaras Gauronskis

Copy No. 1 EN

ANNEX 1 TO CERTIFICATE No. SPSC-9064

Issued 2025-01-23

Product weldable hot rolled reinforcing steel bars
Type B500B,
diameters 10, 12, 14, 16, 20, 25, 28 and 32 mm

Essential characteristics and performances

Essential characteristic	Test method	Performance
Percentage total elongation at maximum force A_{gt} , % (characteristic value)	LST EN ISO 15630-1:2019	5,0
Weldability (product analysis): - carbon equivalent C_{eq} , %; - limitations on the content of certain elements, %	LST EN 10080:2006 spectrometric methods	$\leq 0,52$ pass
Tolerances	LST EN ISO 15630-1:2019	pass
Bendability	LST EN ISO 15630-1:2019	pass
Bonding strength (surface geometry)	LST EN ISO 15630-1:2019	pass
Ratio tensile strength/yield strength R_m / R_e (characteristic value)	LST EN ISO 15630-1:2019	1,08
Tensile yield strength R_e , MPa (characteristic value)	LST EN ISO 15630-1:2019	500
Fatigue, number of stress cycles	LST EN ISO 15630-1:2019	NPD
Durability (product analysis), %: - carbon C; - sulphur S; - phosphorus P; - nitrogen N; - copper Cu; - carbon equivalent C_{eq}	spectrometric method spectrometric method spectrometric method spectrometric method spectrometric method LST EN 10080:2006	$\leq 0,24$ $\leq 0,055$ $\leq 0,055$ $\leq 0,014$ $\leq 0,65$ $\leq 0,52$

Director



Valdemaras Gauronskis